

GOVERNMENT OF TAMILNADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE

Year 2025 - 2026

L.Dis No.000954 /E7/2025

Date : 17/02/2025


I hereby declare that I have inspected the **RAAJAMMAL VIDYALAYA**,
Survey No.174/18, Jawaharlal Nehru Street , Mahalakshmi Nagar, Sevvapet, Thiruvallur District -
602025 building premises on the day 08-02-2025 and certified.

THIS CERTIFICATE IS ISSUED WITH THE FOLLOWING CONDITIONS

1. That the accommodation provided for each of the several classes is sufficient for the maximum number of pupil taught therein and is properly ventilated and lighted.
2. Provide safe drinking water to the Pupils and Staff.
3. That the building is maintained in substantial repair that is neat and clean.
4. That the latrine arrangements are adequate and satisfactory
5. That the supply of drinking water is wholesome and clean.
6. That the premises are free from mosquito and housefly nuisance.
7. That there is no stagnation of waste water.
8. That is all other necessary respects and sanitation is good.
9. Toilets and Urinals should be disinfected daily.
10. Drinking water source should be chlorinated daily.
11. All the class rooms should be disinfected daily as per the existing guidelines of the Government.
12. "No Smoking Area" Sign Board should be displayed in the Building premises.
13. If found any discrimination, the Sanitary Certificate will be Canceled.
14. This certificate is valid for the period of one year from the date of issue.

Counter Signed


District Health Officer
Thiruvallur


BLOCK HEALTH SUPERVISOR,
Upgraded Govt Primary Health Center,
Velliur-601103, Tiruvallur Block & District.

**TEST WATER BEFORE TASTE****TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****District Level Water Testing Laboratory**

TWAD Board, No. 6/24, Lalbhagadur Sasthri St, Periakuppam, Thiruvallur - 602 001

Ph : 044-27663937

TEST REPORT

From

The Assistant Engineer,
TWAD Board,
RWS Sub Division,
Gummidipoondi.

Lr. No. 29683/AE/TWAD/DWTI/TVR/Dt 30.06.2025

To

The Principal,
Raajammal Vidyalaya CBSE School,
174/18, Mahalakshmi Nagar,
Sevvapet Road, Sevvapet - 602025,
Thiruvallur District.

Ref : 1. Your Lr.No.Nil/ Dated: 27.06.2025

2.T.O.Invoice No.15470/Dated.30.06.2025 for 1180/-

The result of analysis for the water samples sent under reference is enclosed!

Source: RO

Location : Raajammal Vidyalaya CBSE School Campus,
Sevvapet.

Date of Collection : 27.06.2025

Date of Receipt : 27.06.2025

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			29683
1. Appearance	-	-	Clean & Clear
2. Colour	5	15	
3. Odour	Agreeable	Agreeable	Agreeable
4. Turbidity NT Units	1	5	0.0
5. Total dissolved Solids mg/L	500	2000	50
6. Electrical Conductivity Micro mho/cm	-	-	71
II. CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	7.05
8. Ph. Alkalinity as CaCO ₃ mg/L	-	-	-
9. Total Alkalinity. as CaCO ₃ mg/L	200	600	28
10. Total Hardness as CaCO ₃ mg/L	200	600	14
11. Calcium as Ca mg/L	75	200	0
12. Magnesium as Mg mg/L	30	100	0
13. Sodium as Na mg/L	-	-	-
14. Potassium as K mg/L	-	-	-
15. Iron as Fe mg/L	0.3	0.3	0.00
16. Manganese mg/L	0.1	0.3	-
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.0
18. Nitrite as NO ₂ mg/L	-	-	-
19. Nitrate as NO ₃ mg/L	45	45	0
20. Chloride as Cl mg/L	250	1000	6
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO ₄ mg/L	200	400	0
23. Phosphate as PO ₄ mg/L	-	-	-
24. Tidy's Test 4 hrs. as O ₂ mg/L	-	-	-
25. Residual chloride	0	1	0.0

Report: 29683: The given water sample is chemically Potable.
30/06/25.**ASSISTANT ENGINEER**
TWAD Board, RWS Sub Division
Gummidipoondi